



2017 ANNUAL DRINKING WATER QUALITY REPORT
 PWSID #: 4110030 NAME: Cresson Borough Water System

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda. (This report contains important information about your drinking water. Have someone translate it for you, or speak with someone who understands it.)

WATER SYSTEM INFORMATION:

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact Mr. Tim Adams, Borough Water Department Foreman or Ms. Roberta Soisson, Office Secretary at (814) 886-2139. We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. Cresson Borough Council meetings are held typically on the second Monday of each month beginning at 7:00 PM at the Cresson Borough Municipal Building. Contact the Secretary at (814) 886-2139 Ext . 102 if the second Monday falls on a holiday for the alternate Borough Council meeting date.

SOURCE(S) OF WATER:

Our water source is:

The Cresson Borough Water System purchases all of its water from the Highland Sewer and Water Authority. The water sources for the Highland sewer and Water Authority are four drilled wells in the Bear Rock watershed and two drilled wells in the Benscreek watershed. Cresson Borough provides no further treatment of the water it purchases from Highland Sewer and Water Authority. The connection to the Highland Sewer and Water Authority system is now located at Sixth Street and Linden Avenue in the Borough. A master water meter, six inches in diameter, measures and records all water purchased by the Borough from Highland Sewer and Water Authority.

A Source Water Assessment of the Highland Sewer and Water Authority system was completed in 2004 by the PA Department of Environmental Protection (Pa. DEP). The Assessment shows that the Highland sources are potentially most susceptible to accidents and spills along the roadways within the assessment areas and to non-point source contamination from residences, pesticide use and past mining practices . Overall, the Highland source(s) have a moderate risk of significant contamination. A summary report of the Assessment is available by writing to Highland Sewer and Water Authority, 120 Tank Drive, Johnstown, PA. 15904 and will eventually be available on the Source Water Assessment Summary Reports eLibrary web page: www.elibrary.dep.state.pa.us/dsweb/View/Collection-10045. Complete reports were distributed to municipalities, water supplier, local planning agencies and PADEP offices. Copies of the complete report are available for review at the Pa. DEP Southwest Regional Office, Records Management Unit at (412) 442-4000.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the *Safe Drinking Water Hotline* (800-426-4791).

MONITORING YOUR WATER:

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2016. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

DEFINITIONS:

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Minimum Residual Disinfectant Level (MinRDL) - The minimum level of residual disinfectant required at the entry point to the distribution system.

Level 1 Assessment – A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment – A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

mrem/year = millirems per year (a measure of radiation absorbed by the body)

ppm = parts per million, or milligrams per liter (mg/L)

pCi/L = picocuries per liter (a measure of radioactivity)

ppq = parts per quadrillion, or picograms per liter

ppb = parts per billion, or micrograms per liter (µg/L)

ppt = parts per trillion, or nanograms per liter

DETECTED SAMPLE RESULTS:

Chemical Contaminants								
Contaminant	MCL in CCR Units	MCLG	Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Trihalo-methanes (TTHMs)	80	NA	10.8	10.8	ppb	9/19/17	N	Byproduct of drinking water chlorination disinfection
Distribution Chlorine	MRDL = 4	4	1.46	0.87 – 1.46	ppm	2017	N	Water additive used to control microbes
Haloacetic acids (five)	60	NA	Less than 2	Less than 2	ppb	9/19/17	N	Byproduct of drinking water chlorination disinfection
Barium (Highland Sewer and Water Authority source)	2	2	0.187	0.157 - 0.187	ppm	3/4/15	N	Erosion of natural deposits; discharge from drilling wastes
Nitrates (Highland Sewer and Water Authority source)	10	10	0	0	ppm	6/15/17	N	Runoff from fertilizer use; leaching from septic tanks; erosion of natural mineral deposits

*EPA's MCL for fluoride is 4 ppm. However, Pennsylvania has set a lower MCL to better protect human health. Please note that Cresson Borough does not add fluoride to its water.

Entry Point Disinfectant Residual							
Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Chlorine	0.5	0.87	0.87 – 1.46	ppm	2017	N	Water additive used to control microbes.

Lead and Copper							
Contaminant	Action Level (AL)	MCLG	90 th Percentile Value	Units	# of Sites Above AL of Total Sites	Violation Y/N	Sources of Contamination
Lead	15	0	1.05	ppb	0	N	Corrosion of household plumbing.
Copper	1.3	1.3	0.174	ppm	0	N	Corrosion of household plumbing.

Microbial (related to Assessments/Corrective Actions regarding TC positive results)					
Contaminants	TT	MCLG	Assessments/ Corrective Actions	Violation Y/N	Sources of Contamination
Total Coliform Bacteria	Any system that has failed to complete all the required assessments or correct all identified sanitary defects, is in violation of the treatment technique requirement	0	See detailed description under "Detected Contaminants Health Effects Language and Corrective Actions" section	N	Naturally present in the environment.

Microbial (related to E. coli)					
Contaminants	MCL	MCLG	Positive Sample(s)	Violation Y/N	Sources of Contamination
<i>E. coli</i>	Routine and repeat samples are total coliform-positive and either is <i>E. coli</i> -positive or system fails to take repeat samples following <i>E. coli</i> -positive routine sample or system fails to analyze total coliform-positive repeat sample for <i>E. coli</i> .	0	0	N	Human and animal fecal waste.
Contaminants	TT	MCLG	Assessments/ Corrective Actions	Violation Y/N	Sources of Contamination
<i>E. coli</i>	Any system that has failed to complete all the required assessments or correct all identified sanitary defects, is in violation of the treatment technique requirement	0	See description under "Detected Contaminants Health Effects Language and Corrective Actions" section	N	Human and animal fecal waste.

Raw Source Water Microbial					
Contaminants	MCLG	Total # of Positive Samples	Dates	Violation Y/N	Sources of Contamination
<i>E. coli</i> (High-land Sewer and Water Authority source)	0	0	2017	N	Human and animal fecal waste.

Information about Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Borough of Cresson is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the *Safe Drinking Water Hotline* or at <http://www.epa.gov/safewater/lead>.

OTHER INFORMATION:

A copy of the Highland Sewer and Water Authority's 2017 Annual Drinking Water Quality Report for the Northern End Well System is available for viewing at the Cresson Borough Municipal Building. The Northern End Well System is the source of supply for the Cresson Borough Water System as described in detail on Page 1 of this Report.

Lead and copper results reported on page 3 were results from sampling done in 2016. Cresson will sample again for lead and copper in 2019 as required by Pa. DEP.
